TRUE COMFORT ||||

This manual covers the following models: • **T705**

Power Type

Battery Power Hardwire (Common Wire) Hardwire (Common Wire) with Battery Backup

Thermostat Applications Guide

Description	
Gas or Oil Heat	Yes
Electric Furnace	Yes
Heat Pump (No Aux. or Emergency Heat)	Yes
Heat Pump (with Aux. or Emergency Heat)	No
Multi-stage Systems	No
Heat Only Systems	Yes
Heat Only Systems - Floor or Wall Furnaces	Yes
Cool Only Systems	Yes
Millivolt	Yes

Table of Contents	Page
Installation Tips Thermostat Quick Reference Subbase Installation Wiring Wiring Diagrams	2 3 4 5 6
Technician Setup	7
Technician Setup Menu	8
Mounting and Battery Installation Programming The Thermostat Programming The Thermostat (cont) Specifications	9 10 11 12

Una versión española de este manual puede ser descargada en www.pro1iaq.com

® U.S. Registered Trademark. Patents pending.
Copyright © 2006 Pro1 IAQ, Inc. All rights reserved.

A trained, experienced technician must install this product.

Carefully read these instructions. You could damage this product or cause a hazardous condition if you fail to follow these instructions.

Need Help?

For assistance with this product please visit http://www.pro1iaq.com or call Pro1 Customer Care toll-free at 888-Pro1iaq (776-1427) during normal business hours (Mon-Fri 9 AM - 6 PM Eastern)








Wall locations

The thermostat should be installed approximately 4 to 5 feet above the floor. Select an area with average temperature and good air circulation.




Do not install thermostat in locations:

- Close to hot or cold air ducts
- That are in direct sunlight
- With an outside wall behind the thermostat
- In areas that do not require conditioning
- Where there are dead spots or drafts (in corners or behind doors)
- Where there might be concealed chimneys or pipes


PRO1 Tip

Pick an installation location that is easy for the user to access. The temperature of the location should be representative of the building.

Getting to know your thermostat




Removing the private label badge



Gently slide a screwdriver into the bottom edge of the badge. Gently turn the screwdriver counter clockwise. The badge is held on by a magnet in the well of the battery door. The badge should pry off easily. **Do not use force.**

All Pro1 thermostats use the same universal magnetic badge. Visit our website at www.pro1iaq.com to learn more about our free private label program.

SUBBASE INSTALLATION







Caution: Electrical Hazard

Failure to disconnect the power before beginning to install this product can cause electrical shock or equipment damage.

Wiring

- 1. If you are replacing a thermostat, make note of the terminal connections on the thermostat that is being replaced. In some cases the wiring connections will not be color coded. For example, the green wire may not be connected to the **G** terminal.
- 2. Loosen the terminal block screws. Insert wires then retighten terminal block screws.
- 3. Place nonflammable insulation into wall opening to prevent drafts.

Terminal Designations

- W Heat relay
- Y Compressor relay
- G Fan relay
- Heat pump changeover valve energized in cooling
- **RC** Transformer power for cooling

RH Transformer power for heating

Warning:

All components of the control

system and the thermostat

installation must conform to

Class II circuits per the NEC Code.

- B Heat pump changeover valve energized in heating
- C Common wire from system transformer

PRO1 Tips:

RH & RC terminals

For single transformer systems, leave the jumper wire in place between RH and RC. Remove jumper wire for two transformer systems.

Heat pump systems

If wiring to a heat pump, use a small piece of wire (not supplied) to connect terminals W and Y.

C terminal

The C (common wire) terminal does not have to be connected when the thermostat is powered by batteries.


Wire specifications

Use shielded or non-shielded 18 - 22 gauge thermostat wire.


A Power supply

- A Factory-installed jumper. Remove only when installing on 2-transformer systems.
- Use either O or B terminals for changeover valve.
- Use a small piece of wire (not supplied) to connect W and Y terminals.
- Set fan operation switch to electric
- Optional 24 VAC common connection when thermostat is used in battery power mode.


Typical 1H/1C system: 1 transformer




Typical 1H/1C heat pump system




Typical heat-only system with fan




Typical 1H/1C system: 2 transformer




Typical heat-only system



Typical cool-only system









Important:

The **RESET** button must be pressed after changing any switch or jumper pin setting. Batteries must be installed for this operation.

Gas or Electric Setup

Gas: For systems that control the fan during a call for heat, put the fan operation switch to the **GAS** position.

Electric: The thermostat operation switch should be put in the **ELEC** position. This setting allows the thermostat to operate the fan when the fan relay is connected to the **G** terminal.

Fahrenheit/Celsius Display

Select **F** or **C** with the jumper pin on the back of the thermostat. **F** is for Fahrenheit and **C** is for Celsius.

12 or 24 Hour Time

12 or 24 hour (military time) can be selected with the jumper pin.



Technician Setup Menu

This thermostat has a technician setup menu for easy installer configuration. To setup the thermostat for your particular application:

- 1. Press MENU button
- 2. Press and hold **TECH SET** button for 3 seconds. This 3 second delay is designed so that homeowners do not accidentally access the installer settings.
- 3. Configure the installer options as desired using the table below.

Use the <u>+</u> or <u>-</u> keys to change settings and the **NEXT STEP** or **PREV STEP** key to move from one option to another. **Note:** Only press **DONE** key when you want to exit the Technician Setup options.

Feature	Filter Change Reminder	Room Temperature Calibration	Minimum Compressor On Time	Compressor Short Cycle Delay	Cooling Swing	Heating Swing
Feature Description	This feature will flash "FILT" in the display after the elapsed run time to remind the user to change the filter. A setting of "off" will disable this feature.	This feature allows the installer to change the calibration of the room temperature display. For example, if the thermostat reads 70° and you would like it to read 72° then select $+2$.	This feature allows the installer to select the minimum run time for the compressor. For example: A setting of 4 will force the compressor to run for at least 4 minutes every time the compressor turns on, regardless of the room temperature.	The compressor short cycle delay protects the compressor from "short cycling". This feature will not allow the compressor to be turned on for 5 minutes after it was last turned off.	The swing setting, often called "cycle rate", "differential" or "anticipation" is adjustable. A smaller swing setting will cause more frequent cycles and a larger swing setting will cause fewer cycles.	The swing setting, often called "cycle rate", "differential" or "anticipation" is adjustable. A smaller swing setting will cause more frequent cycles and a larger swing setting will cause fewer cycles.
LCD Will Show	Next Step	Next Step [] L	Next Step DF F	Next Step	Next Step dF	
Adjustment Options	You can adjust the filter change reminder from "off" to 2000 hours of runtime in 50 hour increments.	You can adjust the room temperature display to read -4°F to + 4°F above or below the factory calibrated reading.	You can select the minimum compressor run time from "off", "3", "4", or "5" minutes. If 3, 4, or 5 is selected, the compressor will run for at least the selected time before turning off.	Selecting "ON" will not allow the compressor to be turned on for 5 minutes after the last time the compressor was on. Select "off" to remove this delay.	The cooling swing setting is adjustable from $\pm 0.4^{\circ}$ F to $\pm 2^{\circ}$ F. For example: A swing setting of 0.5° F will turn the cooling on at approximately 0.5° F above the setpoint and turn the cooling off at approximately 0.5° F below the setpoint.	The heating swing setting is adjustable from $\pm 0.4^{\circ}$ F to $\pm 2^{\circ}$ F. For example: A swing setting of 0.5° F will turn the heating on at approximately 0.5° F below the setpoint and turn the heating off at approximately 0.5° F above the setpoint.
Factory Default Settings	Off	0 °F	Off	On	0.5 °F	0.4 °F

PRO1 Tip

Temperature swing, sometimes called differential or cycle rate, can be customized for this individual application. For most applications choose a swing setting that is as long as possible without making the occupants uncomfortable.


Mount Thermostat

Align the 4 tabs on the subbase with corresponding slots on the back of the thermostat, then push gently until the thermostat snaps in place.



Battery Installation

Battery installation is optional if thermostat is hardwired (C terminal connected).



Set Time

Follow the steps below to set the day of the week and current time:

- 1. Press MENU
- 2. Press SET TIME
- 3. Day of the week will be flashing. Use the + or key to select the current day of the week.
- 4. Press NEXT STEP
- 5. The current hour is flashing. Use the + or key to select the current hour. When using 12-hour time, make sure the correct a.m. or p.m. choice is selected.
- 6. Press NEXT STEP
- 7. Minutes are now flashing. Use the + or key to select current minutes.
- 8. Press DONE when completed

Programming

All programmable Pro1 thermostats are shipped with an energy saving pre-program. You can customize this default program by following the steps below.

Your thermostat can be programmed to have all the weekdays the same, a separate program for Saturday, and a separate program for Sunday. There are four time periods for each program (**WAKE, LEAVE, RETURN, SLEEP**).

Factory Default Program				
Day of the Week	Events	Time	Setpoint Temperature (Heat)	Setpoint Temperature (Cool)
Weekday	Wake 🚮	6 a.m.	70° F (21° C)	75° F (24° C)
	Leave 👬	8 a.m.	62° F (17° C)	83° F (28° C)
	Return 🖬	6 p.m.	70° F (21° C)	75° F (24° C)
	Sleep 👬	10 p.m.	62° F (17° C)	78° F (26° C)
Saturday	Wake 🚮	8 a.m.	70° F (21° C)	75° F (24° C)
	Leave 👬	10 a.m.	62° F (17° C)	83° F (28° C)
	Return 🖬	6 p.m.	70° F (21° C)	75° F (24° C)
	Sleep 👬	11 p.m.	62° F (17° C)	78° F (26° C)
Sunday	Wake 🚮	8 a.m.	70° F (21° C)	75° F (24° C)
	Leave 👬	10 a.m.	62° F (17° C)	83° F (28° C)
	Return is 🕇	6 p.m.	70° F (21° C)	75° F (24° C)
	Sleep 👬	11 p.m.	62° F (17° C)	78° F (26° C)

You can use the table below to plan your customized program schedule.

	Programming Table			
Day of the Week	Events	Time	Setpoint Temperature (Heat)	Setpoint Temperature (Cool)
Weekday	Wake 🚮			
	Leave 👘			
	Return 👬			
	Sleep 🚹			
Saturday	Wake 🚮			
	Leave 👬			
	Return 👬			
	Sleep 🚹			
Sunday	Wake 🚮			
	Leave 🥡			
	Return 👬			
	Sleep 👬			

Set Program Schedule

To customize your program schedule, follow these steps Weekday:

- 1. Select **HEAT** or **COOL** from the system switch. **Note:** You have to program heat and cool each separately.
- 2. Press MENU
- 3. Press **SET SCHED**. Note: Monday-Friday is displayed and the **WAKE** icon is shown. You are now programming the wake time period for the weekday setting.
- 4. Time is flashing. Use the <u>+</u> or <u>-</u> key to make your time selection for the weekday **WAKE** time period.
- 5. Press NEXT STEP
- The setpoint temperature is flashing. Use the + or key to make your setpoint selection for the weekday wake period.

7. Press NEXT STEP

 Repeat steps 4 through 7 for weekday LEAVE time period, for weekday RETURN time period, and for weekday SLEEP time period.

Saturday:

 Repeat steps 4 through 7 for Saturday WAKE time period, for Saturday LEAVE time period, for Saturday RETURN time period, and for Saturday SLEEP time period.

Sunday:

 Repeat steps 4 through 7 for Sunday WAKE time period, for Sunday LEAVE time period, for Sunday RETURN time period, and for Sunday SLEEP time period.

Specifications

The display range of temperature The control range of temperature	
Display accuracy	
Swing (cycle rate or differential)	. Heating is adjustable from 0.4°F to 2.0°F Cooling is adjustable from 0.4°F to 2.0°F
Power source	18 to 30 VAC, NEC Class II, 50/60 Hz for hardwire (common wire) Battery power from 2 AA Alkaline Energizer batteries
Operating ambient	. 32° to +105° (0° to +41°C)
Operating humidity	0
Dimensions of thermostat	. 4.7"W x 4.4"H x 1.1"D

Contact Us

Pro1 IAQ Inc.

1111 S. Glenstone Suite 2-100 Springfield, MO 65804

Toll-free: 1-888-Pro1iaq (776-1427) Toll Number (Outside the USA): 330-821-3600 Web: http://www.pro1iaq.com Hours of Operation: Monday - Friday 9 AM - 6 PM Eastern