

B5/B5 IR-Probe GAS TRANSMITTER/SENSOR



B5



IR-Probe

INSTALLATION OPERATION AND MAINTENANCE MANUAL

QUATROSENSE ENVIRONMENTAL LTD.

5935 OTTAWA STREET, PO BOX 749 (RICHMOND) OTTAWA, ONTARIO CANADA K0A 2Z0

PHONE: (613) 838-4005 FAX: (613) 838-4018

www.QELsafety.com

READ BEFORE OPERATING	2
1. SPECIFICATIONS.....	2
1.1 ELECTRICAL/MECHANICAL SPECIFICATIONS	2
1.2 SENSOR SPECIFICATIONS.....	4
2. INSTALLATION	6
2.1 ENCLOSURES PHYSICAL DIMENSIONS	6
2.2 TERMINALS	6
2.2.1 Wire and Cable.....	7
2.2.2 RS-485 Terminator	7
2.2.3 RS-485 Driver Replacement	7
2.2.4 Relays Output	7
2.2.5 Note for B5:	8
2.2.6 Certification:	8
3. FUNCTION AND CONFIGURATION	9
3.1 INDICATORS	9
3.1.1 RS485-TX/RX:.....	9
3.1.2 Relay 1-3 LED:.....	9
3.2 TOOL FUNCTION	10
3.2.1 Enter Main Menu.....	10
3.2.2 Hush Buzzer and Relay.....	10
3.2.3 Reset Latched/Hushed	10
3.2.4 Reset MENU Password	10
3.2.5 Exit Tool Mode.....	10
3.3 MAIN MENU TREE	11
3.4 MENU “1_SYSTEM SETUP”	12
3.4.1 System Settings	12
3.5 MENU “2_ZERO CAL”	15
3.5.1 Equipment Required.....	15
3.5.2 Zeroing Calibration Procedure.....	15
3.6 MENU “3_SPAN CAL”	16
3.7 MENU “4_OUT TEST”	17
3.8 MENU “5_VIEW SETTING”	18
3.9 MENU “6_ALARM SETUP”	19
3.10 MENU “7_RELAY STYLE”	20
3.11 MENU “8_BUZZER STYLE”	21
3.12 MENU “A_ALL DISABLE”	21
3.13 MENU “B_SIMULATION”	21
3.14 MENU “C_SITE SERVICE” AND “D_FACTROY SET”	21
4. BACNET PIC STATEMENT SUPPORTED BY B5	21
4.1 SMART SENSOR ASSEMBLY REPLACEMENT	22
4.1.1 Disassembling	22
4.1.2 Replacement Procedure	22
4.1.3 Replacement Parts.....	23
4.1.4 Accessories	25
5. TROUBLESHOOTING	26

READ BEFORE OPERATING

All individuals who have or will have the responsibility of using, maintaining, or servicing this product must carefully read this manual. The product will perform as designed only if it is used, maintained, and serviced in accordance with the manufacturer's instructions.

The B5 is a state-of-the-art transmitter that can operate as an independent, stand-alone system or as part of an integrated system. Setup procedures are simplified with user friendly push buttons and LCD menus.

The B5 and the B5 IR-Probe are the Q5 and Q5 IR-Probe with BACnet® MS/TP master protocol. Therefore, the B5 and the B5 IR-Probe do not support the 4-20mA and VDC analog output.

BACnet MS/TP protocol is a peer-to-peer, multiple master protocol based on token passing. Only master nodes are allowed to send and receive tokens on the MSTP network. Passive slave nodes on the other hand may only transmit data frames on the network in response to a request from a master node. Passing the token represents overhead in the sense that the messages used for managing the token do not carry data that is useful to automation or monitoring.

The B5 and the B5 IR-Probe can be set to be a Master Node or a Slave Node in the field. Factory default is slave node.

1. Specifications

1.1 Electrical/Mechanical Specifications

Input Power: 24VDC nominal, range 18 to 30VDC, 0.3A DC Total Max.
24VAC nominal, range 15 to 24VAC, 0.3A AC Total Max.

Fuse: F2 on Main Board: Polyswitch 750mA
Polyswitch device resets after the fault is cleared and power to the circuit is removed.

Sensor: Combustible gases: Catalytic or NDIR
Toxic gases and Oxygen: Electrochemical
Carbon Dioxide: Non-Dispersive Infra-Red (NDIR)

Sampling: Diffusion or Pump-through

Panel Indicators:	5 Status LED's • RS-485 TX Status (Green) • RS-485 RX Status (Green) • Relay1 Status (Red) • Relay2 Status (Red) • Relay2 Status (Red)
Display:	LCD graphic display c/w backlight
Keypad:	3 capacitive touch sensing Keys: F1, F2, F3
Relays:	3 Relays SPDT, Dry contacts • 1.0A maximum at 30 VDC (resistive load) • 0.3A maximum at 125VAC (resistive load)
Buzzer:	80 db at 10 cm, 2700 Hz Buzzer 1, 2, 3: Programmable tone Tone: chirp once / chirp twice / 50% duty cycle / constant ON
Output Signal:	BACnet® MS/TP master /slave protocol
Enclosure Rating:	IP 66 & NEMA 4, 4X, 12 & 13
Operating Temperature:	-40°C to 70°C, depends on sensor specification
Ambient Humidity:	5% to 95% RH (non-condensing)
Storage Temperature:	0°C to 40°C, depends on sensor specification
Size:	150mm X 90mm X 65mm
Weight:	Less than 0.5lbs

1.2 Sensor Specifications

Code	Gas	Symbol	Gas Density	Span	Operating Temperature
16	Methane	CH ₄	Lighter	0 - 100%LEL	-10°C to +50°C
17	Propane	C ₃ H ₈	Heavier	0 - 100%LEL	-10°C to +50°C
18	Hydrogen	H ₂	Lighter	0 - 100%LEL	-10°C to +50°C
*19	Combustible	LEL		0 - 100%LEL	-10°C to +50°C
*20	Ethylene	C ₂ H ₄	Slightly Lighter	0 - 100%LEL	-10°C to +50°C
*21	Iso-Butane	C ₄ H ₁₀	Heavier	0 - 100%LEL	-10°C to +50°C
*22	Iso-Pentane	C ₅ H ₁₂	Lighter	0 - 100%LEL	-10°C to +50°C
*23	Methanol	CH ₃ OH	Lighter	0 - 100%LEL	-10°C to +50°C
*24	Benzene	C ₆ H ₆	Lighter	0 - 100%LEL	-10°C to +50°C
*25	Acetone	CH ₃ CO	Lighter	0 - 100%LEL	-10°C to +50°C
*26	Butanol, n-Butane	BUTAN	Heavier	0 - 100%LEL	-10°C to +50°C

Code	Gas	Symbol	Gas Density	Span	Operating Temperature
0	Oxygen	O ₂		0 - 25%VOL	-30°C to +55°C

Code	Gas	Symbol	Gas Density	Span	Operating Temperature
1	Carbon Monoxide	CO	Slightly Lighter	0 – 250ppm	-20°C to +50°C
1	Carbon Monoxide	CO	Slightly Lighter	0 – 1000ppm	-20°C to +50°C
2	Hydrogen Sulfide	H ₂ S	Heavier	0 – 25ppm	-20°C to +50°C
2	Hydrogen Sulfide	H ₂ S	Heavier	0 – 100ppm	-20°C to +50°C
3	Sulphur Dioxide	SO ₂	Heavier	0 – 6ppm	-20°C to +50°C
5	Nitrogen Dioxide	NO ₂	Heavier	0 – 10ppm	-20°C to +50°C
6	Hydrogen	H ₂	Lighter	0 – 1000ppm	-20°C to +50°C
6	Hydrogen	H ₂	Lighter	0 – 2000ppm	-20°C to +50°C
7	Hydrogen Cyanide	HCN	Lighter	0 – 50ppm	-20°C to +50°C
9	Ammonia	NH ₃	Lighter	0 – 100ppm	-30°C to +50°C
9	Ammonia	NH ₃	Lighter	0 – 1000ppm	-30°C to +50°C
11	Ozone	O ₃	Heavier	0 – 1ppm	-20°C to +40°C
13	Chlorine	Cl ₂	Heavier	0 – 5ppm	-20°C to +50°C
14	Chlorine Dioxide	ClO ₂	Heavier	0 – 2ppm	-20°C to +40°C
96	Arsine	AsH ₃	Heavier	0 – 1ppm	-20°C to +40°C

97	Phosphine	PH ₃	Heavier	0 – 5ppm	-20°C to +40°C
97	Phosphine	PH ₃	Heavier	0 – 1ppm	-20°C to +40°C
98	Silane	SiH ₄	Heavier	0 – 50ppm	-20°C to +40°C
99	Germane	GeH ₄	Heavier	0 – 2ppm	-20°C to +40°C
100	Diborane	B ₂ H ₆	Slightly Lighter	0 – 2ppm	-20°C to +40°C
4	Nitric Oxide	NO	Slighter Heavier	0 – 100ppm	-20°C to +50°C
8	Hydrogen Chloride	HCl	Heavier	0 – 30ppm	-20°C to +40°C
12	Ethylene Oxide	ETO	Heavier	0 – 20ppm	-20°C to +50°C
101	Hydrogen Bromide	HBr	Heavier	0 – 30ppm	-20°C to +40°C


Code	Gas	Symbol	Gas Density	Span	Operating Temperature
15	Carbon Dioxide	IR-CO ₂	Heavier	0 – 5000ppm	-20°C to +50°C
15	Carbon Dioxide	IR-CO ₂	Heavier	0 – 5%VOL	-20°C to +50°C
15	Carbon Dioxide	IR-CO ₂	Heavier	0 – 20%VOL	-20°C to +50°C
15	Carbon Dioxide	IR-CO ₂	Heavier	0 – 100%VOL	-20°C to +50°C
16	Methane	IR-CH ₄	Lighter	0 – 100%LEL	-20°C to +50°C
16	Methane	IR-CH ₄	Lighter	0 – 100%VOL	-20°C to +50°C

*NOTE: Mounting Heights

- Low = 9-18 inches (0.25-0.5 meters) from floor
- Mid = 4-6 feet (1.25-1.75 meters) from floor
- High = 9-18 inches (0.25-0.5 meters) from ceiling


2. Installation

2.1 Enclosures Physical Dimensions



The enclosure is a NEMA 4 rated enclosure and can be wall mounted with 4 screws. To maintain the NEMA rating, it is important that the conduit opening is sealed upon installation.

2.2 Terminals



B5 Terminals

2.2.1 Wire and Cable

Terminal blocks TB1 to TB7 accept 12 AWG to 24 AWG wire. Use 16 AWG or 18 AWG wire for the power supply in long wiring runs, which can be up to 1km (1,000 meters) long.

We recommend using BELDEN 9841 for communications. This wire has 120 ohm input impedance, which will eliminate RS-485 communication problems.

2.2.2 RS-485 Terminator

The terminator on each end of the RS485 run is designed to match the electrical impedance characteristic of the twisted pair wire, and will prevent signal echoes from corrupting the data on the line. The terminator should be enabled on BOTH ends of the RS485 run. Short and medium length ModBus/485 runs can operate without the terminating resistor. Longer runs may require the terminating resistors. But adding terminator dramatically increases power consumption.

Factory default setting is disabled terminator.

The B5 supplies this resistor on the main board, and it is chosen using a jumper at J4.

- J4 1-2: Terminator Disabled / OFF (default)
- J4 2-3: Terminator Enabled / ON

2.2.3 RS-485 Driver Replacement

RS-485 lines in heavy industrial environments are sometimes subjected to magnetic disturbances causing sufficient inducted power surges to damage the driver integrated circuit (IC). This IC (U6) has a socket on the circuit card for ease of replacement in the field.

2.2.4 Relays Output

The B5 has three onboard programmable Single-Pole Double-Throw (SPDT) relays. These relays can be used to control other equipment, such as fans, lights, horns, etc. eliminating the need for a separate controller.

Three terminal blocks (TB1, TB2 and TB3) are located on the main board. Each relay can be programmed individually.

Switching capability of each relay is:

- 1.0 A maximum resistive load at 30 VDC
- 0.3A maximum resistive load at 125VAC

2.2.5 Note for B5:

The B5 supports BACnet MS/TP protocol and can be networked to form a BACnet MS/TP network.

The B5 default baud rate is 38400bps.

Each B5 on the MS/TP network must have a unique BACnet MAC address and unique Device Instance Number (Object ID).

- B5 valid MAC addresses are 0-127 for master node, 0-254 for slave node.
- B5 default MAC address is 126.
- Default Device Instance Number (Object ID) is 4005.

The B5 power supply and RS-485 connection are similar to the Q5. The B5 doesn't have terminal blocks TB4 and TB6.

Avoid running communication wires or sensor input wires next to AC power wires or the relay output wires. These can be sources of noise that can affect signal quality.

When the B5 input power is AC, the 24VAC can be either grounded or non-grounded. Polarization is very important when the B5 is connected to a network. Make sure the Neutral is connected to the GND of TB5.

2.2.6 Certification:

The Q5/B5 series have been certified to the following Standard:

Safety requirement for Electrical Equipment for Measurement, Control, and Laboratory Use- Part 1: General Requirements CAN/CSA-22.2 No. 61010-1 Third Edition, Dated May 11, 2012;
And

Safety Requirements for Electrical Equipment for measurement, Control, and Laboratory Use- Part 1: General Requirements UL 61010-1 Third Edition, Dated May 11, 2012.

Installation must be in accordance with ANSI/NFPA 70, National Electrical Code (NEC); the


Canadian Electrical Code (CEC), Part I, CSA C22.1, and CSA C22.2 No. 0; and the Manufacturers' installation instructions

The Q5/B5 series have not been tested for Life Safety Applications and are not to be used in Life Safety Applications in jurisdictions that require this certification.

3. Function and Configuration

3.1 Indicators

The indicators consist of five LED's – two to indicate RS-485 digital communication, three to indicate the status of relays 1-3.



3.1.1 RS485-TX/RX:

When the B5 is connected to a controller system via RS-485, the traffic of the communication can be monitored visually through the two RS-485 indicators. One is RX LED, which indicates the data stream received in from the controller. The other is TX LED, which indicates the data stream out of the B5.

Note: If the TX LED or the RX LED is always ON, is indicative of a communication problem. See Troubleshooting for RS-485.


3.1.2 Relay 1-3 LED:

Indicate the status of each relay. When the relay is actuated/closed, the relay LED is ON. When the relay is de-actuated/open, the relay LED is OFF.

Note: If you set the relay to be Normally Energized (Fail Safe), the relay LED will turn ON at non-alarm state and turn OFF at alarm state, because the LED reflects the relay coil status.

3.2 Tool Function

Press key [F3] to enter tool functions that might be used frequently in the field.



3.2.1 Enter Main Menu

Press key [F1] to browse previous item of the current menu.

Press key [F2] to browse next item of the current menu.

Press key [F3] to enter the main menu for more configuration and settings.

3.2.2 Hush Buzzer and Relay

Press key [F3] to silence the buzzer and buzzer-style relays.

3.2.3 Reset Latched/Hushed

To acknowledge a latched condition or a hushed condition, press key [F3] to reset latched relays and hushed buzzer for which the alarm condition has been removed. If the alarm condition (e.g. high gas concentration) is still present the relay(s) will not reset.

3.2.4 Reset MENU Password

If you forgot the main menu password, you can reset the menu password to default password “4321” by entering a correct active code. For the active code, contact QEL.

3.2.5 Exit Tool Mode


Press key [F3] to return to monitoring mode.

3.3 Main Menu Tree

The main menu is password protected. Once the password is accepted, you are allowed into the main menu tree.

Factory default password is 4321.

Note: While in the menu tree, all normal monitoring operations stop. The alarm status does not change.



3.4 Menu “1_SYSTEM SETUP”

The system setup subdivision contains general settings for monitor operations, communications and 4-20mA calibrations.

3.4.1 System Settings

Password:	Default password is 4321.
MAC Address:	The B5 RS-485 address can be defined from 0 to 255. B5 default address is 126.
Object ID:	BACnet Device Instance Number. Default is 4005.
Baud rate:	Define baud rate for RS-485 communication with BACnet protocol. B5 default baud rate is 38400 bps.
Scroll Rate:	In normal operation, the sensor and relay status information scrolls automatically. Set the number of seconds for each item to be displayed. Default value is 3 seconds.
Backlight:	The LCD backlight can be set to Always Off, Always On and Auto Power Saving mode. In Auto Power Saving mode, the backlight will turn on for 10 seconds after any key has been pressed. Default setting is Always ON.
UTC Offset	The B5 supports the execution of the TimeSynchronization service and UTCTimeSynchronization service. It indicates the number of minutes (- 780 to +780) offset between local standard time and Universal Time Coordinated. Default is +300 (US & Canada Eastern Time).
Daylight Saving	It indicates whether daylight saving time is in effect (Enabled) or not (Disabled) at the B5 location in UTCTimeSynchronization service. Default is Enabled.
New Password:	The new password can be any combination of up to four digits. Default password is 4321. Warning: Be sure that you record the new password in a safe and secure location!
Protocol:	The B5 supports BACnet MS/TP master or slave protocol. Default is MS/TP master.

Display Mode:	• Display Instant: displays instantaneous gas concentration • Display Average: ○ Displays STEL (15min average reading) ○ Displays TWA (8 hour average reading) ○ Displays daily peak • Display Alarm: displays alarm 1-8 status • Display Relay: displays relay 1-3 status • Display Buzzer: displays buzzer 1-3 status • Display A-Out mA: displays current 4-20mA output • Display A-Out VDC: displays current VDC output • Display Clock: displays real time clock If there is nothing to display, the unit will display “Running...”
Auto Zero:	When AutoZero is set to ON, the unit will gather the lowest reading in 7-day period and set the unit into Zeroing Calibration mode so that the lowest reading goes to zero. When AutoZero is set to OFF, the unit will not adjust its own zero and work off the last manual or factory calibration. Default value is OFF. NOTE: AutoZero works best in situations where the building will purge at night (or over a weekend) to a zero concentration of target gas.
Key Beeper:	ON: Beeping when keypad is touched OFF: No beeping when keypad is touched
Restore Default:	Note: Don't do this if you don't have calibration gas and precision reference instrumentation to calibrate the unit. To load defaults to factory settings, to restore the unit to correct operation. The settings below will be restored to default values: -Password, -Baud rate, -Scroll rate, -Backlight, -Display mode, -Key beeper, -LCD contrast, -Gas type on the Sensor Board, -Alarm settings, -Relay/Buzzer settings, and 4-20mA/1-5VDC settings. The unit needs to change the gas type if the sensor on the sensor board is not the default gas type: CO, CH4 or O2. Contact QEL for instructions. Zero and span calibrations are needed.

ADJ Clock:	Adjust real time clock. The B5 supports the execution of the TimeSynchronization service and UTCTimeSynchronization service. The clock can be adjusted remotely.
ADJ Contrast:	Adjust the LCD contrast. Valid values are between 10 (light) and 50 (dark). Default is 21.
Check Battery	The sensor board is equipped with a coin battery. This setting will enable or disable the B5 to check the battery voltage and beep for a low battery level. Default is ON.
Output Priority:	Alarm output (BV) present_value and relay output (BO) present_value support command prioritization. The B5 has priority #12 as default. The lower the priority number the more critical the nature of the output. Priority #1 is considered the highest priority. Priority #16 is the lowest priority.

3.5 Menu “2_ZERO CAL”

The B5 is calibrated using a two-point calibration process. First, use a “Zero Gas”, then use a “CAL Gas” containing a known concentration of a standard reference gas, to set the second point of reference.

3.5.1 Equipment Required

- A cylinder of Zero Gas, (clean air or nitrogen).
- A cylinder of Cal Gas
- Flow Limiting Regulator(s) **0.2 to 1.0 lpm**
- Tubing

3.5.2 Zeroing Calibration Procedure

- “2_ZERO CAL:”

2_ZERO CAL

- Press key [F3] and the device will show the calibration notice and then ask if you want to continue. The middle line will display the current concentration.

CONTINUE?
XXPPM

- Apply the Zero Gas.
- Wait for about 3 minutes or until the reading is stable.
- Press key [F3] to confirm Zeroing Cal.
- When the device is in Zeroing CAL, it will take 3 seconds to 20 seconds to complete.
- When the zeroing CAL operation is over, the device will display “Accepted” and return to “2_ZERO CAL”.
- Make sure there is no Cal Error displayed. If Cal Error is reported, repeat the procedures above. If the Cal Error is still showed up, the sensor may be expired.
- Remove the gas.
- Exit the menu to Monitoring Mode.

3.6 Menu “3_SPAN CAL”

- “3_ SPAN CAL”

3_ SPAN CAL

- Press key [F3] and the device will ask for the CAL GAS, input the concentration of the calibration gas.

CAL GAS:	XXX
>	

- Press key [F3] and the device will show the calibration notice and then show the flow rate for the span calibration. Press any key to continue, and then the device will ask you if you want to continue. The middle line will display the current concentration.

CONTINUE?
XXPPM


- Apply the calibration gas.
- Wait for about 3 minutes or until the reading is stable.
- Press key [F3] to confirm SPAN CAL.
- When the device is in span cal, it will take 10 seconds to 1 minute to complete.
- When the span cal operation is over, the device will display “Accepted” and return to “3_SPAN CAL”.
- Make sure there is no Cal Error displayed. If Cal Error is reported, repeat the procedures above. If the Cal Error is still showed up, the sensor maybe expired.
- Remove the gas.
- Exit menu to Monitoring Mode.

3.7 Menu “4_OUT TEST”

During system installation and testing, it may be necessary to force relays and buzzers on and off.


The Relay Testing feature allows the user to force the actuation of each relay. This function forces an Actuate vs. De-actuate action, not an energized vs. non-energized action. Therefore the user must be aware of these relays, which have been defined as normally energized or not normally energized.

The 4mA (1VDC/2VDC) and 20mA (5VDC/10VDC) outputs can be tested too.



3.8 Menu “5_VIEW SETTING”

This function is to verify the settings for the alarms, relays, buzzers and analog outputs.



3.9 Menu “6_ALARM SETUP”

The B5 supports alarm 1 to alarm 8.

Alarm is a programmable condition that can receive a selectable input and trigger relays and buzzers.

Disabled or Enabled:	Each alarm may be individually set to be enabled or disabled. If the alarm is disabled, the alarm will not be used to calculate or trigger anything. Default: Alarm 1 to Alarm 4 is enabled. Alarm 5 to Alarm 8 is disabled.
Input:	One of five inputs is selected to calculate the alarm condition status to trigger the selected outputs: • INSTANT: instantaneous gas reading. • 15 MIN AVG (STEL): Short Term Exposure Limit, average reading over 15 minutes. • 8 HOURS AVG (TWA): 8-hour Time Weighted Average, average reading over 8 hours. • DAILY PEAK: daily peak reading. • FAULT: If the unit reports any faults, no matter the gas concentration, it will trigger the selected outputs.
Alarm On and Alarm Off Reading:	<i>If Alarm On is greater than or equal to Alarm Off:</i> Alarm On: Sets the concentration at or above which the relay will actuate. Alarm Off: Sets the concentration at or below which the relay will de-actuate. <i>If Action On is less than Action Off:</i> Action On: Sets the concentration below that the relay will actuate. Action Off: Sets the concentration above that the relay will de-actuate.
Trigger:	Trigger Outputs: Relay 1, Relay 2, Relay 3, Buzzer 1, Buzzer 2, Buzzer 3

3.10 Menu “7_RELAY STYLE”

Enabled:	Each relay may be individually set to be enabled or disabled. If it's disabled, the relay will always de-actuate no matter what the current gas concentration. Default is Enabled.
Normally De-energized:	Each relay may be individually set to be normally energized or normally de-energized. Default is normally de-energized.
Latching:	Each relay may be set to latch in actuate status until acknowledged by a front-panel action. Default is Non-Latching.
ON Delay:	“Delay on Actuation” or “Delay on Make”. For each relay a separate time delay may be set from 0 to 990 seconds before an alarm condition will cause the relay to actuate. Default is 5 seconds.
OFF Delay:	“Delay on De-Actuation” or “Delay on Break”. For each relay a separate time delay may be set from 0 to 990 seconds before a return to a non-alarming signal condition will cause the relay to de-actuate. Default is 5 seconds.
Style:	Normal Relay Style: Work as normal relay. Buzzer Style Relay: When the relay is used to control a buzzer or horn. Working as a buzzer style will make the relay have the same function as the buzzer. It will be switched off when performing the Hush Buzzer/Relay function in the Tool Menu. Default is OFF.

3.11 Menu “8_BUZZER STYLE”

The buzzer style is almost identical to that of the relays, except the style that represents the buzzer tone options:

- Tone 1: Chirp once.
- Tone 2: Chirp twice.
- Tone 3: Intermittent 50% duty cycle.
- Tone 4: Continuous.

The menus are identical to those for the Relay Style.

3.12 Menu “A_ALL DISABLE”

This function is for calibration, system testing etc. When All Disable is ON, the status of the relay, buzzer and analog output, etc., will freeze in their current state.

Default is OFF.

3.13 Menu “B_SIMULATION”

Simulation mode is used to assist in testing the installation before commissioning. When simulation is enabled, the unit will not detect gas concentrations; it will display the simulated value and use it to calculate the status of relays and buzzers. This feature is available for evaluating the user settings and testing the installation (e.g.: the activation of the valve, fan speed, relay set points, etc. can be verified.)

Any concentration between 0ppm and 9999ppm can be simulated.

3.14 Menu “C_SITE SERVICE” and “D_FACTORY SET”

Factory service staff access only. The customer has no need to operate it.


4. BACnet PIC Statement Supported By B5

See document: 85950-103-000 (B5 PIC Statement).

4.1 Smart Sensor Assembly Replacement

4.1.1 Disassembling

Observe all safety and electrical codes and regulations before removing enclosure lid.



Important: Calibrate the transmitter whenever a component is replaced. But if you replace a smart sensor assembly with a sensor onboard from QEL, you don't need to recalibrate the transmitter, as all the calibration information has been stored in the smart sensor board in the factory process.

4.1.2 Replacement Procedure

To replace the entire smart sensor assembly, complete the following steps:

1. Power down the transmitter.
2. Remove the four screws securing the enclosure lid assembly to the base enclosure and remove the enclosure lid assembly.
3. Remove the two screws securing the smart sensor board and remove the smart sensor board from the lid assembly
4. Feed the O-ring over the sensor on the new smart sensor assembly
5. Plug the new smart sensor assembly and secure with two screws. Ensure that the connectors are correctly matched. Incorrect installation may damage the sensor assembly and/or the display board.

4.1.3 Replacement Parts

Code	Gas	Symbol	Span	Smart Sensor Assembly
0	Oxygen	O2	0 - 25%VOL	85930-016-000


Code	Gas	Symbol	Span	Smart Sensor Assembly
16	Methane	CH4	0 - 100%LEL	85930-017-016
17	Propane	C3H8	0 - 100%LEL	85930-017-017
18	Hydrogen	H2	0 - 100%LEL	85930-017-018
*19	Combustible	LEL	0 - 100%LEL	85930-017-019
*20	Ethylene	C2H4	0 - 100%LEL	85930-017-020
*21	Iso-Butane	C4H10	0 - 100%LEL	85930-017-021
*22	Iso-Pentane	C5H12	0 - 100%LEL	85930-017-022
*23	Methanol	CH3OH	0 - 100%LEL	85930-017-023
*24	Benzene	C6H6	0 - 100%LEL	85930-017-024
*25	Acetone	CH3CO	0 - 100%LEL	85930-017-025
*26	Butanol, n-Butane	BUTAN	0 - 100%LEL	85930-017-026

Code	Gas	Symbol	Span	Smart Sensor Assembly
1	Carbon Monoxide	CO	0 – 250ppm	85930-018-001
1	Carbon Monoxide	CO	0 – 1000ppm	85930-018-201
2	Hydrogen Sulfide	H2S	0 – 25ppm	85930-018-002
2	Hydrogen Sulfide	H2S	0 – 100ppm	85930-018-202
3	Sulphur Dioxide	SO2	0 – 6ppm	85930-018-003
5	Nitrogen Dioxide	NO2	0 – 10ppm	85930-018-005
6	Hydrogen	H2	0 – 1000ppm	85930-018-006
6	Hydrogen	H2	0 – 2000ppm	85930-018-206
7	Hydrogen Cyanide	HCN	0 – 50ppm	85930-018-007
9	Ammonia	NH3	0 – 100ppm	85930-018-009
9	Ammonia	NH3	0 – 1000ppm	85930-018-209
11	Ozone	O3	0 – 1ppm	85930-018-011
13	Chlorine	Cl2	0 – 5ppm	85930-018-013
14	Chlorine Dioxide	ClO2	0 – 2ppm	85930-018-014
96	Arsine	AsH3	0 – 1ppm	85930-018-096
97	Phosphine	PH3	0 – 5ppm	85930-018-097
97	Phosphine	PH3	0 – 1ppm	85930-018-297
98	Silane	SiH4	0 – 50ppm	85930-018-098
99	Germane	GeH4	0 – 2ppm	85930-018-099
100	Diborane	B2H6	0 – 2ppm	85930-018-100


Code	Gas	Symbol	Span	Smart Sensor Assembly
4	Nitric Oxide	NO	0 – 100ppm	85930-018-004
8	Hydrogen Chloride	HCl	0 – 30ppm	85930-018-008
12	Ethylene Oxide	ETO	0 – 20ppm	85930-018-012
101	Hydrogen Bromide	HBr	0 – 30ppm	85930-018-101

Code	Gas	Symbol	Span	Smart Sensor Assembly
15	Carbon Dioxide	IR-CO2	0 – 5000ppm	85930-019-015
15	Carbon Dioxide	IR-CO2	0 – 5%VOL	85930-019-215
15	Carbon Dioxide	IR-CO2	0 – 20%VOL	85930-019-315
15	Carbon Dioxide	IR-CO2	0 – 100%VOL	85930-019-415
16	Methane	IR-CH4	0 – 100%LEL	85930-019-016
16	Methane	IR-CH4	0 – 100%VOL	85930-019-216


4.1.4 Accessories



Pump-thru &
Calibration Cap Kit
SKU#: 85930-006-000



Splash Guard Kit
SKU#: 85930-007-000



Duct Mount Adapter Kit
SKU#: 85930-040-000

Free stand or Duct mount IR-Probe

Note: For Duct Mount Installation, B5 needs both the Pump-thru Kit and Duct Mount Kit.

5. Troubleshooting

This troubleshooting guide is intended as an aid in identifying the cause of unexpected behavior and determining whether the behavior is due to normal operation or an internal or external problem.

SYMPTOMS	PROBABLE CAUSE	SUGGESTED SOLUTION
RS-485 RX LED or TX LED constantly ON	• RS-485 bus connection has a problem • RS-485 driver U6 is damaged • Controller side RS-485 driver has problem	• Disconnect the cable to isolate the problem • Replace U6 IC on main board • Replace the RS-485 driver on the controller
No response to gas	• Sensor screen is dirty • Sensor has expired	• Clean sensor opening • Replace smart sensor assembly, see Replacement Parts
Apparent false alarm	• Puff of gas • Not properly calibrated • Solvent fumes or interference from high levels of interfering gas • Radio frequency interference	• Monitor is functioning • Recalibrate • Remove source of interfering gas • Check that grounding and shielding is correct

WARRANTY STATEMENT

The information contained in this manual is based upon data considered accurate; however, no warranty is expressed or implied regarding the accuracy of this data. All QEL equipment is warranted against defects in material and workmanship for a period of two years from date of shipment with the following exceptions:

Electrochemical Sensors (Toxic)	Six Months
Catalytic Sensors (Combustible)	One Year

During the warranty period we will repair or replace, at our discretion, any components or complete units that prove, in our opinion, to be defective. We are not liable for consequential or incidental damage to auxiliary interfaced equipment.

A returned material authorization number should be obtained from the factory prior to returning any goods. All return shipments must be shipped freight prepaid and a copy of the maintenance records should accompany the unit concerned.

Warranty should be considered F.O.B. the factory. Labour and travel time are chargeable for any field site visits required for warranty work.

LIMITED LIABILITY

All QEL systems shall be installed by a qualified technician/electrician and maintained in strict accordance with data provided for individual systems in the form of installation/maintenance manuals. QEL assumes no responsibility for improper installation, maintenance, etc., and stresses the importance of reading all manuals. QEL shall not be responsible for any liability arising from auxiliary interfaced equipment nor any damage resulting from the installation or operation of this equipment.

QEL's total liability is contained as above with no other liability expressed or implied, as the purchaser is entirely responsible for installation and maintenance of systems.

This warranty is in lieu of all other warranties, expressed or implied, and no representative or person is authorized to represent or assume for QEL any liability in connection with the sales of our products other than that set forth herein.

NOTE: Due to on-going product development, QEL reserves the right to change specifications without notice and will assume no responsibility for any costs as a result of modifications.

For further information or assistance, contact:

QUATROSENSE ENVIRONMENTAL LTD.

5935 Ottawa Street, PO Box 749

Richmond, Ontario

K0A 2Z0

Tel: (613) 838-4005

Fax: (613) 838-4018

Email: QEL@QELsafety.com

Web: www.QELsafety.com